
Declaration of test results

2015-Efectis-R000112-D

Efectis Nederland BV hereby declares that

IsoBouw SlimFort®,
covered by aluminium profiles and Rockpanel mounted with open joint

has been investigated according to:

EN 11925-2:2010

“Reaction to fire tests - Ignitability of products subjected to direct impingement of flame. Part 2: Single-flame source test”

and

EN 13823:2010

“Reaction to fire tests for building products - Building products excluded floorings exposed to the thermal attack by a single burning item”

In accordance with the European fire classification standard
EN 13501-1:2007+A1:2009 the product is classified as:

B - s1, d0

The complete details of the tests performed are recorded in Efectis test report
2014-Efectis-R0351a and 2015-Efectis-R000111.

This declaration is valid until:

February 2020

This declaration is assigned to:

IsoBouw Systems BV
P.O. Box 1
5710 AA SOMEREN
THE NETHERLANDS

Place and date:

Bleiswijk, 6 February, 2015

On behalf of Efectis Nederland BV:



A.J. Lock
Project leader reaction to fire